



## KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB, THODUPUZHA, IDUKKI-685585

Phone : 04862220719

(NABL Recognized Sub Divisional Level Government Drinking Water Testing Laboratory)

### WATER TEST REPORT

- qcsdtdpa@gmail.com

Report Issue Date : 13.06.2025

DE PAUL PUBLIC SCHOOL THODUPUZHA EAST P O THODUPUZHA			Date of Receipt of Payment	10.06.2025		
			Date of Sample Received	10.06.2025		
			Sampling Given by	Costumer		
			Sample Code	TDPA 484		
			Sample Name	Well Water		
			Sample Condition	Good		
			Source of Sample	Well		
			Sample Quantity	2 Litre		
			Test performing date	From 11.06.2025 to 11.06.2025		
Sl.No	Characteristics	Unit		Acceptable Limit as per IS 10500-2012	Permissible limits in absence of alternate source	Result
1	Turbidity	(NTU)	IS 3025 (Part10)-2023	1.0	5.0	0.11
2	P <sup>H</sup> at 25 °C		IS 3025 (Part 11)-2022	6.5 to 8.5	No relaxation	6.44
3	Chloride (as Cl)	(mg/litre)	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	1000	22.7
4	Total Hardness (as CaCO <sub>3</sub> )	(mg/litre)	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	600	80.80

#### Remark

NB:-The result stated above related only to the sample(s) submitted for testing by the customer. The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Analysed By



**CHEMIST**  
Quality Control Subdistrict Lab  
Kerala Water Authority  
Thodupuzha - 685 585

KWA/QCSDL/TDPA/F/6	Issue : 1	Issue Date : 01.07.2021
Rev. No: 12	Rev.Date : 09.10.2024	Page 1 of 3



## KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB, THODUPUZZHA, IDUKKI-685585

Phone : 04862220719

### WATER TEST REPORT

- qcSDLtdpa@gmail.com

Report Issue Date :13.06.2025

DE PAUL PUBLIC SCHOOL THODUPUZZHA EAST P O THODUPUZZHA			Date of Receipt of Payment	10.06.2025		
			Date of Sample Received	10.06.2025		
			Sampling Given by	Customer		
			Sample Code	TDPA 484		
			Sample Name	Well Water		
			Sample Condition	Good		
			Source of Sample	Well		
			Sample Quantity	2 Litre		
			Test performing date	From 11.06.2025 to 11.06.2025		
Sl.No	Characteristics	Unit		Acceptable Limit as per IS 10500-2012	Permissible limits in absence of alternate source	Result
1	Nitrate (as NO <sub>3</sub> )	(mg/litre)	Phenol Di- Sulphonic Acid Method	45	No relaxation	25.80
2	Iron (as Fe)	(mg/litre)	IS 3025 (Part 53)-2024	1	No relaxation	0.33
3	Electrical conductivity at 25°C	(micromhos/cm)	IS 3025(Part 14)-2013 (Reaffirmed 2019)	-	-	240.70

#### Remark :

NB:-The result stated above related only to the sample(s) submitted for testing by the customer. The test certificate shall not be reproduced except in full without the written approval of the Laboratory.




Analysed By

*Shagor*

**CHEMIST**

Quality Control Subdistrict Lab  
Kerala Water Authority  
Thodupuzha - 685 585





## KERALA WATER AUTHORITY

Phone :04862220719

QUALITY CONTROL SUB DISTRICT LAB,THODUPUZZHA IDUKKI-685585

WATER TEST-BACTERIOLOGY REPORT

email-qcsdlttdpa@gmail.com

KWA/QCSDL/TDPA/F/6/484/25-26		Report Issue Date : 13.06.2025		
Customer Name & Address		Date of Receipt of payment	10.06.2025	
DE PAUL PUBLIC SCHOOL THODUPUZZHA EAST P O THODUPUZZHA		Date of Sample recived	10.06.2025	
		Sampling Given by	Customer	
		Sample Code	TDPA 484	
		Sample Name	Well Water	
		Sample Condition	Good	
		Source of Sample	Well	
		Sample Quantity	200 ml	
		Test performing dates	From: 10.06.2025 to 12.06.2025	
Sl. No.	Source	Test Method	No of Total Coliforms per 100ml of sample	E.Coli in 100ml of sample
1	Water sample submitted by the customer	IS 15185:2016 (Reaffirmed 2021)	Present	Absent

Remarks:-

NB:-The result stated above related only to the sample(s) submitted for testing by the customer.The test certificate shall not be reproduced except in full without the written approval of the Laboratory.



Analysed by  
Name & Designation

Divya PS

KWA/QCSDL/TDPA/F/05	Issue : 1	Issue Date : 01.07.2021
Rev. No: 1	Rev.Date : 01.03.2022	Page 3 of 3

End of Report